



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

शिक्षा मंत्रालय, भारत सरकार द्वारा स्थापित

सेक्टर 81, नॉलेज सिटी, प० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब - 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Estd. By Ministry of Education, Govt of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K GST No. 03AAAAI1781K2ZS

• Phone : +91-172-2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

[CPPP/Institute Website](http://www.iisermohali.ac.in)

IISERM(1655)23/24-Pur

Dated : 01-03-2024

शुद्धिपत्र -II / CORRIGENDUM –II

In reference to the e-Tender notice no. IISERM(1655)23/24-Pur dated 24-01-2024 towards “**Providing of Networking Services and related Core Infrastructure for New Hostel in IISER Mohali**”, invited IISER Mohali, Knowledge City, PO. Manauli S.A.S. Nagar, Mohali, Punjab-140306, the Bid submission date is further extended due amendment in NIT, responses to representations received against the above NIT as given below and revised schedule :

Sl. No.	Representation	Response
1.	On pages 25, 30, and 33 it is noted that “Passive network components: All passive network components (IO Ports, cat cables, fibres, racks, patch panel, patch cord etc.) should be from one OEM. Please exclude racks from this clause. Passive OEM’s and Racks OEMs are different.”	This should be read as: Passive network components: All passive network components (IO Ports, cat cables, fibres, patch panel, patch cord etc.) should be from one OEM. Racks could be preferably from the same OEM as other passive components.
2.	On pages 25, 30, and 33 it is noted that: Electrical components: Electrical components (wires, conduit, PVC pipes, plugs, sockets, UPS etc) should be from one OEM. Please remove this clause. These are all accessories will be from different vendors, Like electrical wires, sockets, plugs can be from one vendor, whereas UPS can be from another and PVC Pipes, Conduit from some other vendor. This clause is in page no 25 & 33 as well	This should be read as: Electrical components (wires, conduit, PVC pipes, plugs, sockets, UPS etc) preferably from one OEM.
3.	Equipment: Bidders should have Splicing, OTDR/OLTS, and Penta scans machines in-house. The bidder must provide an undertaking document on their letterhead. Please amend this clause to Bidders should have expertise for carrying out activities (Splicing, OTDR/OLTS, and Penta scans).	The item sl. No. 8 should be read as: In-house Equipment: The bidder should preferably have splicing, OTDL/OLTS and Penta scans machines in-house OR should have in-house expertise for carrying out fiber laying out capabilities (Splicing, OTDR/OLTS, and Penta scans). The same should be provided on a letter head.

4.	<p>Response to 2nd representation:</p> <p>"The vendor may offer alternative solutions for connecting DS-to-AS over fiber (instead of Cat6A) to address the distance limitation as per their proposals. Fiber connectivity is permitted, but the proposed bandwidth must be maintained in every sector of networking mentioned in the tender document. The vendors providing the fiber solution should ensure compatibility among all connectors, cables, and switch types, as well as with the devices already specified in the tender. It is important to note the following:</p> <ul style="list-style-type: none"> • It is required that vendors should use separate (independent) sets of optical fibers for wired and wireless connections between respective DS-to-AS connections. • The vendor should note that the fibre solution may not need Cat6a cables, and respective accessories and therefore, vendor must make appropriately changes, wherever it is required (as mentioned in the document). • The evaluation criteria would be the same as mentioned elsewhere in the tender."
----	--

Revised date and Time:

S. No.	Description	Extended Due date/Time
01	Closing Date & Time (Online) submission	11th March 2024 upto 02:30 PM
02	Opening Date & Time of Technical Bid	12th March 2024 upto 03:30 PM

For any information, other modifications and/or corrigendum may kindly visit IISER Mohali websites <http://www.iisermohali.ac.in/> & CPPP portal <https://eprocure.gov.in/eprocure/app>.

Bidders are requested to furnish bid incorporating the above changes/ amendment/s.

Sd/-
 सहायक कुलसचिव (क्रय तथा भंडार)
Assistant Registrar (Stores & Purchase)