

BOQ

Sub: Providing sensor to existing LPG supply line in AB-1 at IISER Mohali

S. No	Description of Items	Qty	Unit	Rate	Amount
1	P/f of valve 1/2", ISI marked of MAKE ACRON	2	nos		
2	P/f of Gas leakage sensor (Make- Ambetroces) GT-4000 FLP/3 wire flame proffer for LPG/PNG all complete as per direction of Engineer-in-Charge	1	no		
3	P/f of chanal sensor panel with control wiring all complete as per direction of Engineer-in-Charge	1	no		
4	P/f of Solonoid valve 1" manual operated ISI marked for LPG gas line all complete as per direction of Engineer-in-Charge	1	no		
5	P/f of hooter, ISI marked with control cable all complete as per direction of Engineer-in-Charge	1	no		
6	P/f of hand shut valve for pressure control (MAKE UNITED) for LPG line all complete as per direction of Engineer-in-Charge	4	no		
	Total				

Contractor