



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित

सैक्टर 81, नॉलेज सिटी, प० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Established by Ministry of Human Resource Development, Govt. of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K GST No. 03AAAAI1781K1ZT

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

[CPPP/Institute Website](http://www.iisermohali.ac.in)

IISERM (882)17/18-Pur

Dated :16.10.2017

NOTICE INVITING E-TENDER

Online tenders are invited on behalf of Director, IISER Mohali in **SINGLE BID SYSTEM** for **Supply and Installation of Class A2 Biosafety Cabinet** from reputed companies/firms/ individuals/ societies etc. those are in the similar business at CPPP i.e. <https://eprocure.gov.in/eprocure/app>. Tender documents may please be downloaded from the E-procurement portal website <https://eprocure.gov.in/eprocure/app>& Institute website www.iisermohali.ac.in.

-sd-

(Mukesh Kumar)

Assistant Registrar (S&P)



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित
सैक्टर 81, नॉलेजसिटी, प० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Established by Ministry of Human Resource Development, Govt. of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K GST No. 03AAAAI1781K1ZT

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

CPPP/Institute Website

E-TENDER NOTICE

Tender Ref.- IISERM(882)17/18-Pur

Dated :- 16th October 2017

Critical Date Sections

Sr.	Description	Date	Time
1.	Tender Publishing Date and time	16 th October 2017	6:00pm
2.	Tender Document download start Date & Time	16 th October 2017	6:00pm
3.	Bid Submission start Date & Time	16 th October 2017	6:00pm
4.	Bid Submission End date and Time	30 th October 2017	Up to 11:00am
5.	Tender opening Date and Time	31 st October 2017	At 11.30 am

Online tenders are invited on behalf of the Director, IISER Mohali in **SINGLE BID SYSTEM** for following item(s) from the original manufacturer/supplier at CPPP i.e. <https://eprocure.gov.in/eprocure/app>. Tender documents may please be downloaded from the E-procurement portal website <https://eprocure.gov.in/eprocure/app> & Institute website www.iisermohali.ac.in. Tender fee in shape of DD/Banker Cheque of Rs 500/- (Non-refundable) and EMD of Rs.2000/- should be submitted by DD /Banker Cheque/FDR/ Bank Guarantee in favour of the Registrar, IISER Mohali payable at Mohali. However, scanned copy of the both tender fee and EMD should be upload on website along with technical bid part. The hard copy of the same in original to be send to the address mentioned below duly superscribing the supply/work name and reference/ tender ID on the envelope and same must reach before opening the bid and if not received within due date the bid will be rejected summarily.

The Original EMD and tender fee should be sent to:

Assistant Registrar (S&P)
Indian Institute of Science Education and Research,
Mohali Sector 81, SAS Nagar, Mohali, Punjab,
India, Pin: 140306

Non-receipt of original EMD and tender fee will lead to rejection of tender.

Item Details:

Sr. No.	Details of Specifications of the Stores	Qty.
1)	<p>Supply and Installation of Class II Type A2 Biosafety Cabinet</p> <p><u>Technical Specifications :</u></p> <ol style="list-style-type: none">1. Class II Type A2, 4 feet with minimum 8 inch work aperture2. Stainless Steel interior cabinet surface, manual adjustable height stand, Should include a germicidal UV lamp, set of arm rest3. The cabinet shall incorporate HEPA filters for supply and exhaust air, providing efficiency of 99.99%4. Alarm & display for choked filters, change in differential pressure and air flow block.5. Display of real time performance data such as air velocities, hours of operation, filter status, safe window position, UV light indicator and activation with timer, activation of power receptacles, fluorescent light activation. Stoppage/reduction in flow velocity on closing of sash.6. Motor should be DC ECM & must automatically adjust the airflow speed (balancing inflow and down flow) without the use of a damper to ensure continuous safe working conditions.7. The microprocessor based Cabinet should use differential pressure sensor to display the inflow and down flow air velocities in real-time on an LED/LCD display.8. Should have port for vacuum tubing and cables on the sides.9. DC motor technology should be there in biological safety cabinet and should not consume more than 220 watt.10. UV light must be programmable to allow for specific exposure times from 0 to 24 hours. Lightening power should >1100 Lux (100fc); cabinet noise level must be less than 65 dB.11. Cabinet should be NSF/ANSI 49, UL, CE certified and certificate of the quoted model should be attached.12. Warranty: 3 years13. AMC & CMC Should be quote as optional14. System to be supplied with compatible stabilizer15. User list must be attached	01 No.

SUBMISSION OF TENDER

- I. All bid/ tender documents are to be uploaded online at Central Public Procurement portal i.e. <https://eprocure.gov.in/eprocure/app> only and in the designated cover/ part on the website against tender ID. Tenders/ bids shall be accepted only through online mode and no manual submission of the same shall be entertained except tender fee and EMD. Late tenders will not be accepted.

- II. The online bids shall be opened at the office of the Assistant Registrar (P&S), IISER Mohali, on above given date and time. If the tender opening date happens to be on a holiday or non-working day due to any other valid reason, the tender opening process will be attended on the next working day at same time and place. IISER Mohali will not be responsible for any error like missing of schedule data while downloading by the Bidder.
- III. The bidder shall upload the tender documents duly filled in and stamped by the authorized signatory on each and every page. Tender not submitted/uploaded in the prescribed form and as per the tender terms and conditions shall be liable for rejection.
- IV. The bidder shall upload scanned copy of the PAN Card, GST number VAT return, Service tax registration number duly signed and stamped.
- V. E-procurement system ensures locking on the scheduled date and time. The system will not accept any bid after the scheduled date and time of submission of bid.

INSTRUCTIONS

1. The Online bids should be submitted directly by the original manufacturer/supplier, If quotation is submitted/filled by any representative/agent/dealer then they must upload a authority certificate from the principal company for quoting the price otherwise such quotation will be rejected.
2. The quantity mentioned in this inquiry is and shall be deemed to be only approximate and will not in any manner be binding on the Institute. Before the deadline for submission of the online bid, IISER Mohali reserves the right to modify the tender document terms and conditions. Such amendment/modification will be notified on website against said tender ID.
3. The rates offered should be FOR Chandigarh/Mohali in case of firms situated outside Chandigarh/Mohali, and free delivery at the Institute premises in case of local firms. Supplier from outside India should mention the Ex-works/FOB/FCA/CIF/CIP price clearly. Conditional tenders will be summarily rejected.
4. In case of Ex-godown terms the amount of packaging forwarding freight etc. should clearly be indicated by percentage or lump sum amount. Institute has policy not to make any advance payments towards any purchase, Letter of credit can be opened if required.
5. THE INSTITUTE IS EXEMPTED FROM EXCISE AND CUSTOM DUTY under notification no- TU/V/RG-CDE(1062)1 201–CUSTOM DATED 30.08.2016.
6. Tax: This Institute is not exempted from the payment of GST. The current rate (i.e. percentage of GST should be clearly indicated included or excluded) wherever chargeable. Please also provide/upload the copy of PAN card, GST number duly self-attested.
7. The bidder are quote and indicate the prices in [**Euro/Dollars**] wherever applicable in Technical Bid furnished along the tender documents.

8. The delivery period should be specifically stated. Earlier delivery will be preferred.
9. The firms are requested to provide/upload detailed description and specifications together with the detailed drawings, printed leaflets and literature of the article quoted. The name of the manufactures and country of manufacture should also invariably be stated. In the absence of these particulars, the quotation is liable for rejection.
10. Validity of offer: 90 days. The warranty period after satisfactory installation should be mentioned and firm should replace all manufacturing defect parts/ whole item under warranty without any extra cost including clearance, freight, taxes. Security deposit/ Bank Performance Guarantee @ 10 % of the value of supply order as per norms may be sought from the firms.
11. The right to reject all or any of the quotation and to split up the requirements or relax any or all the above conditions without assigning any reason is reserved by the IISER Mohali. For any corrigendum and addendum please be checked the website <https://eprocure.gov.in/eprocure/app> and <http://www.iisermohali.ac.in>
12. Disputes, if any, shall be subject to jurisdiction in the court of Mohali only.

-sd/-
(Mukesh Kumar)
Assistant Registrar (S&P)