



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली
मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित
सैक्टर 81, नॉलेज सिटी, पं० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306
INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI
(Established by Ministry of Human Resource Development, Govt. of India)
Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab
PAN No. - AAAAI1781K

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

IISERM (884)17/18Pur.

30th October 2017

Corrigendum-I

Refer IISER Mohali E-tender Ref. no. IISERM (884)17/18 Pur for **Supply and Installation of Water Cooled Chiller Plant** at IISER Mohali, Sector-81, Knowledge City, PO-Manauli, SAS Nagar Mohali, Punjab. Due date for the online submission is extended due to **Revised Technical Specification** as per below details.

Revised Technical Specification:

Sr. No.	Details of Specifications of the Stores	Qty.
1)	<p>Supply and Installation of Air Cooled Chiller Plant Comprising of Air cooled chiller plant in the range of 20- 24 TR capacity comprising pump 3HP (Kirloskar), with 2 nos(1 in line & 1 standby) of 10 Micron filter as per GPM of chiller water outlet, with SS-304 housing along with electronic panel. Piping SS-304 1 1/2" - 2" (100Mtr make Jindal/Sirsa/Bhushan/Tata) and SS-304 pipe 1" (40Mtr make Jindal/Sirsa/Bhushan/Tata) with SS-304 accessories such as Hexa nipple(as per site requirement), SS-304 ball valve (14 nos Make-Audco/Advance)of required size all complete as desired by the faculty.</p> <p>(Make : Carrier, Blue Star, Trane, Voltas)</p> <p><u>General Conditions :</u></p> <ol style="list-style-type: none">1. Time of execution of 10 weeks including erection and commissioning.2. The above quantities for piping are likely to increase or decrease. In case if quantity decreases prorata recovery shall be made as per market rate. For any increase in length nothing shall be paid.3. The agency must have successfully undertaken installation of chiller plant valuing of Rs.7.5 lakh in any Govt/ Autonomous bodies/PSU otherwise bid shall be rejected.4. The agency/bidder should have average annual financial turn over not less than Rs. 15 Lakh. During last three year ending 31st March 20175. The agency/bidder should not back listed from any Govt./Centre Govt./State Govt./PSU/Institute.	01 No.

	6. Performance guarantees to be taken for at least 10% value of the order. 7. WARRANTY: Two years	
--	--	--

Revised Date and Time

Sr.no.	Description	Extended Due date/Time
01	Closing Date & Time (Online)	09/11/2017 up to 11:00 AM
02	Opening Date & Time of Technical Bid	10/11/2017 at 11:30 AM

All the other terms & conditions will remain same as contained in the NIT.

For any information, other modifications and/or corrigendum may kindly visit IISER Mohali websites <http://www.iisermohali.ac.in> & <https://eprocure.gov.in/eprocure/app>

Sd/-
Mukesh Kumar
Assistant Registrar (S&P)