



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित

सैक्टर 81, नॉलेजसिटी, प०ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Established by Ministry of Human Resource Development, Govt. of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K TAN No. PTL10692D

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

CPPP/Institute Website

IISERM (999)18/19-Pur

Dated :17.04.2018

NOTICE INVITING E-TENDER

Online tenders are invited on behalf of Director, IISER Mohali in **TWO BID SYSTEM** for **Supply and Installation of Portable Helium Leak Detector with both vacuum and Sniffer operation** from reputed companies/firms/ individuals/ societies etc. those are in the similar business at CPPP i.e.. Tender documents may please be downloaded from the E-procurement portal website <https://eprocure.gov.in/eprocure/app> & Institute website www.iisermohali.ac.in.

-sd-

(Mukesh Kumar)

Assistant Registrar (S&P)



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित

सैक्टर 81, नॉलेज सिटी, प० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Established by Ministry of Human Resource Development, Govt. of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K TAN No. PTL10692D

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

CPPP/Institute Website

E-TENDER NOTICE

Tender Ref.- IISERM(999)18/19-Pur

Dated :- 17th April, 2018

Critical Date Sections

Sr.	Description	Date	Time
1.	Tender Publishing Date and time	17 th April, 2018	6:00pm
2.	Tender Document download start Date & Time	17 th April, 2018	6:00pm
3.	Bid Submission start Date & Time	17 th April, 2018	6:00pm
4.	Bid Submission End date and Time	3 rd May 2018	Up to 11:00am
5.	Tender opening Date and Time	4 th May 2018	At 11.30 am

Online tenders are invited on behalf of the Director, IISER Mohali in **TWO BID SYSTEM** for following item(s) from the original manufacturer/supplier at CPPP i.e. <https://eprocure.gov.in/eprocure/app>. Tender documents may please be downloaded from the E-procurement portal website <https://eprocure.gov.in/eprocure/app> & Institute website www.iisermohali.ac.in. Tender fee in shape of DD/Banker Cheque of Rs 500/- (Non-refundable) and EMD of Rs.20000/- should be submitted by DD /Banker Cheque/FDR/ Bank Guarantee in favour of the Registrar, IISER Mohali payable at Mohali. However, scanned copy of the both tender fee and EMD should be upload on website along with technical bid part. The hard copy of the same in original to be send to the address mentioned below duly superscribing the supply/work name and reference/ tender ID on the envelope and same must reach before opening the bid and if not received within due date the bid will be rejected summarily.

The Original EMD and Tender Fee should be sent to:

Assistant Registrar (S&P)
Indian Institute of Science Education and Research,
Mohali Sector 81, SAS Nagar, Mohali, Punjab,
India, Pin: 140306

Non-receipt of original EMD and Tender Fee will lead to rejection of tender.

Item Details:

S. No.	Details of Specifications of the Stores	Qty.
1.	<p><u>Supply and Installation of Portable Helium Leak Detector with both vacuum and Sniffer operation</u></p> <p><u>Specification for Portable Helium Leak Detector</u></p> <ol style="list-style-type: none"> Fully automated, efficient, TMP based and portable Dry Helium leak detector. Must have direct access to key functions and should be portable in any orientation for its transportation. The vendors are encouraged to quote for both the options as given below. Option 1 will get more preference depending on the availability of funds. <p><u>Option: 1</u></p> <p>Portable Helium Leak detector with both vacuum and Sniffer operation</p> <ol style="list-style-type: none"> Lowest detectable helium leak rate: Vacuum operation : $\leq 3.0 \times 10^{-11}$ mbar lits/sec Sniffer operation : $< 7.0 \times 10^{-9}$ mbar lits/sec Sniffer length including sniffer : quote for all possible lengths 1. module ranging from 4-50 meter.) Measurement ranges : 12 decades Maximum permissible inlet pressure : 15 mbar Helium pumping speed in fine mode : 3.1 lit/sec Time constant for leak rate signal : < 1.0 sec Time unit ready for operation : Maximum 2-3 mins Inlet flange : 25 mm DIN standard flange <p>Warranty : 24 months Warranty for all parts from the date of delivery.</p> <p><u>Option: 2</u></p> <p>Portable Helium Leak detector with only Sniffer operation</p> <ol style="list-style-type: none"> Lowest Detectable Helium leak Rate : $< 5.0 \times 10^{-6}$ mbar lits/sec Response Time : < 2 seconds Recovery time : < 10 sec Start Up time : < 03 min <p>Warranty : 24 months Warranty for all parts from the date of delivery.</p>	1 No.

- The online updated Price BOQ is in INR format. If bidder want to quote other than INR please specify the quoted currency in the technical bid/part and fill the amount in same updated BOQ.
- Please bifurcate the price on shipping terms i, e, Ex-works -> FCA/FOB -> CIP/CIF in price BOQ and specify the same in technical bid.

SUBMISSION OF TENDER

- I. All bid/ tender documents are to be uploaded online at Central Public Procurement portal i.e. <https://eprocure.gov.in/eprocure/app> only and in the designated cover/ part on the website against tender ID. Tenders/ bids shall be accepted only through online mode and no manual submission of the same shall be entertained except tender fee and EMD. Late tenders will not be accepted.
- II. The online bids shall be opened at the office of the Assistant Registrar (P&S), IISER Mohali, on above given date and time. If the tender opening date happens to be on a holiday or non-working day due to any other valid reason, the tender opening process will be attended on the next working day at same time and place. IISER Mohali will not be responsible for any error like missing of schedule data while downloading by the Bidder.
- III. The bidder shall upload the tender documents duly filled in and stamped by the authorized signatory on each and every page. Tender not submitted/uploaded in the prescribed form and as per the tender terms and conditions shall be liable for rejection.
- IV. The bidder shall upload scanned copy of the PAN Card, GST number, Service tax registration number duly signed and stamped.
- V. E-procurement system ensures locking on the scheduled date and time. The system will not accept any bid after the scheduled date and time of submission of bid.

INSTRUCTIONS

1. The Online bids should be submitted directly by the original manufacturer/supplier, If quotation is submitted/filled by any representative/agent/dealer then they must upload a authority certificate from the principal company for quoting the price otherwise such quotation will be rejected.
2. The quantity mentioned in this inquiry is and shall be deemed to be only approximate and will not in any manner be binding on the Institute. Before the deadline for submission of the online bid, IISER Mohali reserves the right to modify the tender document terms and conditions. Such amendment/modification will be notified on website against said tender ID.
3. The rates offered should be FOR Chandigarh/Mohali in case of firms situated outside Chandigarh/Mohali, and free delivery at the Institute premises in case of local firms. Supplier from outside India should mention the Ex-works/FOB/FCA/CIF/CIP price clearly. Conditional tenders will be summarily rejected.
4. In case of Ex-godown terms the amount of packaging forwarding freight etc. should clearly be indicated by percentage or lump sum amount. Institute has policy not to make any advance payments towards any purchase, Letter of credit can be opened if required.
5. THE INSTITUTE IS EXEMPTED FROM EXCISE AND CUSTOM DUTY under notification no- 51/96 –CUSTOM DATED 23/7/1996 AND DSIR REGISTRATION NO TU/V/RG/-CDE(1062)/2011 DT. 02/09/2011 / EXCISE NOTIFICATION NO. 10/97- CENTRAL EXCISE DT. 01.03.1997.
6. GST Exemption - MINISTRY OF FINANCE, (DEPARTMENT OF REVENUE) Notification No.45/2017- Central Tax (Rate) dated 14th November, 2017 47/2017-Integrated Tax (Rate) 14th

November, 2017 for purpose of availing concession in rate of GST admissible to Scientific/Research and academic Institutions.

7. Bidder/s quoting in currency other than **Indian Rupee (INR)** should explicitly mention the currency in which tender quoted wherever applicable in Technical Bid along the tender documents.
8. The delivery period should be specifically stated. Earlier delivery will be preferred.
9. The firms are requested to provide/upload detailed description and specifications together with the detailed drawings, printed leaflets and literature of the article quoted. The name of the manufactures and country of manufacture should also invariably be stated. In the absence of these particulars, the quotation is liable for rejection.
10. Validity of offer: 90 days. The warranty period after satisfactory installation should be mentioned and firm should replace all manufacturing defect parts/ whole item under warranty without any extra cost including clearance, freight, taxes. Security deposit/ Bank Performance Guarantee @ 10 % of the value of supply order as per norms may be sought from the firms.
11. The right to reject all or any of the quotation and to split up the requirements or relax any or all the above conditions without assigning any reason is reserved by the IISER Mohali. For any corrigendum and addendum please be checked the website <https://eprocure.gov.in/eprocure/app> and <http://www.iisermohali.ac.in>
12. Disputes, if any, shall be subject to jurisdiction in the court of Mohali only.

—sd/-
(Mukesh Kumar)
Assistant Registrar (S&P)