



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित

सैक्टर 81, नॉलेज सिटी, प० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Established by Ministry of Human Resource Development, Govt. of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K TAN No. PTL10692D

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

CPPP/Institute Website

IISERM (1002)18/19-Pur

Dated :02.05.2018

NOTICE INVITING E-TENDER

Online tenders are invited on behalf of Director, IISER Mohali in **TWO BID SYSTEM** for **Supply and Installation of Water Chiller for Helium Plant** from reputed companies/firms/ individuals/ societies etc. those are in the similar business at CPPP i.e.. Tender documents may please be downloaded from the E-procurement portal website <https://eprocure.gov.in/eprocure/app> & Institute website www.iisermohali.ac.in.

-sd-

(Mukesh Kumar)
Assistant Registrar (S&P)



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन विकास मंत्रालय, भारत सरकार द्वारा स्थापित

सैक्टर 81, नॉलेज सिटी, प० ओ० मनोली, एस० ए० एस० नगर, मोहाली, पंजाब 140306

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI

(Established by Ministry of Human Resource Development, Govt. of India)

Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab

PAN No. - AAAAI1781K TAN No. PTLI10692D

• Phone : +91-172-2240086 & 2240121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

CPPP/Institute Website

E-TENDER NOTICE

Tender Ref.- IISERM(1002)18/19-Pur

Dated :- 02nd May, 2018

Critical Date Sections

Sr.	Description	Date	Time
1.	Tender Publishing Date and time	02 nd May, 2018	6:00pm
2.	Tender Document download start Date & Time	02 nd May, 2018	6:00pm
3.	Bid Submission start Date & Time	02 nd May, 2018	6:00pm
4.	Bid Submission End date and Time	22 nd May 2018	Upto 11:00am
5.	Tender opening Date and Time	23 rd May 2018	At 11.30 am

Online tenders are invited on behalf of the Director, IISER Mohali in **TWO BID SYSTEM** for following item(s) from the original manufacturer/supplier at CPPP i.e. <https://eprocure.gov.in/eprocure/app>. Tender documents may please be downloaded from the E-procurement portal website <https://eprocure.gov.in/eprocure/app> & Institute website www.iisermohali.ac.in. Tender fee in shape of DD/Banker Cheque of Rs 500/- (Non-refundable) and EMD of Rs.20000/- should be submitted by DD /Banker Cheque/FDR/ Bank Guarantee in favour of the Registrar, IISER Mohali payable at Mohali. However, scanned copy of the both tender fee and EMD should be upload on website along with technical bid part. The hard copy of the same in original to be send to the address mentioned below duly superscribing the supply/work name and reference/ tender ID on the envelope and same must reach before opening the bid and if not received within due date the bid will be rejected summarily.

The Original EMD and Tender Fee should be sent to:

Assistant Registrar (S&P)
Indian Institute of Science Education and Research,
Mohali Sector 81, SAS Nagar, Mohali, Punjab,
India, Pin: 140306

Non-receipt of Original EMD and Tender Fee will lead to rejection of tender.

Item Details:

S. N.	Details of Specifications of the Stores		Qty
Supply and Installation of Water Chiller for Helium Plant			01 No.
Technical Specification for water chiller:			
1	Media to be cooled	Soft water	
2	Cooling Capacity	15 TR	
3	Operating temperature	+5 °C to +47 °C	
4	Required Temperature	+15 °C	
5	Chilled water Outlet	+15 °C	
6	Ambient Temperature	+47 °C	
7	Refrigerant	R 407C (Eco Friendly), R 22	
8	Water Tank	- SS304 Construction, Absolutely Rusting Free, Should have a drain port at the bottom with a valve	
9	Water Flow Rate	150 lpm	
10	Condenser	Air cooled	
11	Fan	- Air Cooled, Heavy duty, Axial Flow	
12	Gas piping	Interconnected refrigerant pipe of copper Structural stand for compressor, condenser, liquid receiver, chiller etc. All components must be absolutely rusting free.	
13	Control panel	Electro-Mechanical with fault Indications, complete with rotary switch, contractors, connectors, wiring etc	
14	Safety interlocks	- LP switch & Gauge, HP switch & Gauge, Compressor Overload trip, Digital temperature Controller (Compressor cut in & cut off as per set temperature in the controller) Water Level Low Trip etc. Single phase prevention trip	
15	End connections – Inlet/outlet, Installation and commission	1 inch. All completely rusting free materials to be used.	
16	Type of Expansion Device	Thermostatic expansion valve	
17	Warranty	Minimum 2 years	
18	AMC	3 years	

Other Terms:**The Vendor should also supply following items:-**

1. All the water pipeline and connectors should be made of rust free material.
2. A water flow control bypass line should be connected.
3. A digital water flow meter should be connected in the chiller.
4. A 10-micron water filter should be connected to the outlet of the water chiller.
5. 1 inch pipe with its insulation, clamps and with other required fittings is about 100 meter approx.
6. The vendor should also provide the necessary fittings, valves etc at the time of installation.
7. The outlet of the chiller is 1 inch wide but our inlet of the machine which is to be cooled is 0.25 inch so vendor should also provide the adaptor/manifold from 1 inch to 0.25 inch with valves, clamps and other required fittings as per site requirements.
8. The maximum supply time should not exceed 8 weeks by the date of PO generated.
9. The above quantities for piping are likely to increase or decrease
10. The vendor must have successfully undertaken installation of chiller plant valuing Rs.7.5 Lakh in any two Govt/Autonomous body/PSU otherwise bid shall be rejected.

SUBMISSION OF TENDER

- I. All bid/ tender documents are to be uploaded online at Central Public Procurement portal i.e. <https://eprocure.gov.in/eprocure/app> only and in the designated cover/ part on the website against tender ID. Tenders/ bids shall be accepted only through online mode and no manual submission of the same shall be entertained except tender fee and EMD. Late tenders will not be accepted.
- II. The online bids shall be opened at the office of the Assistant Registrar (P&S), IISER Mohali, on above given date and time. If the tender opening date happens to be on a holiday or non-working day due to any other valid reason, the tender opening process will be attended on the next working day at same time and place. IISER Mohali will not be responsible for any error like missing of schedule data while downloading by the Bidder.
- III. The bidder shall upload the tender documents duly filled in and stamped by the authorized signatory on each and every page. Tender not submitted/uploaded in the prescribed form and as per the tender terms and conditions shall be liable for rejection.
- IV. The bidder shall upload scanned copy of the PAN Card, GST number, Service tax registration number duly signed and stamped.
- V. E-procurement system ensures locking on the scheduled date and time. The system will not accept any bid after the scheduled date and time of submission of bid.

INSTRUCTIONS

1. The Online bids should be submitted directly by the original manufacturer/supplier, If quotation is submitted/filled by any representative/agent/dealer then they must upload a authority certificate from the principal company for quoting the price otherwise such quotation will be rejected.
2. The quantity mentioned in this inquiry is and shall be deemed to be only approximate and will not in any manner be binding on the Institute. Before the deadline for submission of the online bid, IISER Mohali reserves the right to modify the tender document terms and conditions. Such amendment/modification will be notified on website against said tender ID.
3. The rates offered should be FOR Chandigarh/Mohali in case of firms situated outside Chandigarh/Mohali, and free delivery at the Institute premises in case of local firms. Supplier from outside India should mention the Ex-works/FOB/FCA/CIF/CIP price clearly. Conditional tenders will be summarily rejected.
4. In case of Ex-godown terms the amount of packaging forwarding freight etc. should clearly be indicated by percentage or lump sum amount. Institute has policy not to make any advance payments towards any purchase, Letter of credit can be opened if required.
5. THE INSTITUTE IS EXEMPTED FROM EXCISE AND CUSTOM DUTY under notification no- 51/96 –CUSTOM DATED 23/7/1996 AND DSIR REGISTRATION NO TU/V/RG/-CDE(1062)/2011 DT. 02/09/2011 / EXCISE NOTIFICATION NO. 10/97- CENTRAL EXCISE DT. 01.03.1997.
6. Tax: This Institute is not exempted from the payment of GST. The current rate (i.e. percentage of GST should be clearly indicated included or excluded) wherever chargeable. Please also provide/upload the copy of PAN card, GST number duly self-attested.

7. Bidder/s quoting in currency other than **Indian Rupee (INR)** should explicitly mention the currency in which tender quoted wherever applicable in Technical Bid along the tender documents.
8. The delivery period should be specifically stated. Earlier delivery will be preferred.
9. The firms are requested to provide/upload detailed description and specifications together with the detailed drawings, printed leaflets and literature of the article quoted. The name of the manufactures and country of manufacture should also invariably be stated. In the absence of these particulars, the quotation is liable for rejection.
10. Validity of offer: 90 days. The warranty period after satisfactory installation should be mentioned and firm should replace all manufacturing defect parts/ whole item under warranty without any extra cost including clearance, freight, taxes. Security deposit/ Bank Performance Guarantee @ 10 % of the value of supply order as per norms may be sought from the firms.
11. The right to reject all or any of the quotation and to split up the requirements or relax any or all the above conditions without assigning any reason is reserved by the IISER Mohali. For any corrigendum and addendum please be checked the website <https://eprocure.gov.in/eprocure/app> and <http://www.iisermohali.ac.in>
12. Disputes, if any, shall be subject to jurisdiction in the court of Mohali only.

-sd/-
(Mukesh Kumar)
Assistant Registrar (S&P)