



भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान मोहाली

मानव संसाधन एवं विकास मंत्रालय, भारत सरकार द्वारा स्थापित
सैक्टर 81, नॉलेज सिटी, पी. ओ. मनोली, एस. ए. एस. नगर, मोहाली, पंजाब –140306
INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH MOHALI
Sector-81, Knowledge city, PO-Manauli, SAS Nagar Mohali-140306, Punjab
PAN NO. - AAAAI1781K TAN NO. PTLI10692D

IISER Mohali

• Phone : +91-172-2240086,121 • Fax : +91-172-2240124, 2240266 • <http://www.iisermohali.ac.in> • Email: stores@iisermohali.ac.in

E-mail/CPMP/Website

IISERM(624)15/16 Pur

25th January 2016

TENDER NOTICE

Sealed Quotations in **TWO BID SYSTEM** (Technical & Financial) under separate envelope are invited on behalf of Director IISER Mohali for the following items along with EMD money by DD /Banker Cheque/ FDR/ Bank guarantee for Rs 15000/- and tender fee of Rs 500/- (separately non-refundable) in favour of the Registrar, IISER Mohali, so as to reach us latest by **15th February 2016** before 1pm and will be opened on the same day at 4pm. in the presence of tenderers, if any :-

Sr	Description	Qty
01	<p><u>10KVA UPS system</u> (Input side power factor to be unity with input voltage range 291V-551V and output voltage 230VAC\pm 1% in signal phase) with: External SMF batteries 42AH/12V (26 NOS) including close cabinet with 4 fans and wheels., Type true online - Double conversion, 3 phase input 1 phase output.</p> <p>Inverter overload – 110% for 60 min, 125% for 10 min, 150% for 1 min. with maintenance by pass switch.</p> <p>Output– Inbuilt isolation between UPS and connected load, Inbuilt isolation transformer with input output cable.</p> <p>(Multistran by copper cable of 10SQ. MM- 4Core Plus 4sqmm*1 (Earthing cable) for input supply from panel to UPS- 10mtrs and 10SQ. mm- 2Core plus 4sqmm *1 (Earthing cable) for output supply from UPS to panel-10mtrs. Approx.). Front voltage surge spickes protection.</p> <p>Immune to reverse phase sequence. LCD display with 200 event logging for fault diagnostic. IGBT rectifier. Input power factor 0.99 to unity.</p> <p>IP-21, Environment Audible noise <55 dBA at 1 mtr distance from panel.</p> <p><u>General</u></p> <p>Authorization certification from OEM</p> <p>Warranty 2 years on UPS and 2 Years on batteries.</p> <p>Bids: Submission under two bids or else bids will be rejected.</p> <p>Make: Emerson/ Liebert / APC/ Gutor/ Merline Gerin/ Mitsubhishi</p>	02 nos

Sd/-
(Mukesh Kumar)
Assistant Registrar (S&P)

INSTRUCTIONS

1. The Quotation should be addressed to the Assistant Registrar (S&P), IISER Mohali invariably giving on the envelop Reference number with due date and time of submission of quotation.
2. One time importers from China with custom made specifications are highly discouraged.
3. The quantity mentioned in this inquiry is and shall be deemed to be only approximate and will not in any manner be binding on the Institute.
4. The rates offered should be FOR Chandigarh/Mohali in case of firms situated outside Chandigarh/Mohali, and free delivery at the Institute premises in case of local firms. Supplier outside India please mentions the Ex-works/FOB/FCA/CIF/CIP price clearly.
5. In case of Ex-godown terms the amount of packaging forwarding freight etc should clearly be indicated by percentage or lump sum amount. Institute has policy not to make any advance payments towards any purchase, Letter of credit can be opened if required.
6. THE INSTITUTE IS EXEMPTED FROM EXCISE AND CUSTOM DUTY.
7. SALES TAX :- This Institute is not exempted from the payment of Sales Tax/Service Tax/VAT. The current rate (i.e. percentage of Sales Tax should be clearly indicated included or excluded) wherever chargeable.
8. The delivery period should be specifically stated. Earlier delivery will be preferred
9. The firms are requested to give detailed description and specifications together with the detailed drawings, printed leaflets and literature of the article quoted. The name of the manufactures and country of manufacture should also invariably be stated. In the absence of these particulars, the quotation is liable for rejection.
10. Validity of offer: 90 days. Firm should replace all manufacturing defect parts/ whole item under warranty period without any extra cost including clearance, freight, taxes. Security deposit/ Bank Performance guarantee for 10 % of the value of supply order as per norms may be sought from firms.
11. Late or delayed quotation will not be accepted.
12. The right to reject all or any of the quotation and to split up the requirements or relax any or all the above conditions without assigning any reason is reserved. For any corrigendum and addendum please regularly visit our website.